

Electrical data

## **Voltage Transducer CV 4-4000**

For the electronic measurement of voltages: DC, AC, pulsed..., with galvanic isolation between the primary circuit and the secondary

# $U_{PN} = 2828 \text{ V}$



Liecti icai data			
$U_{PN}$	Primary nominal RMS voltage	2828	V
$U_{\rm PM}$	Primary voltage, measuring range	0 ±4000	V
$U_{\mathtt{S}}$	Secondary voltage	10	V
S	Sensitivity	4000 / 10	V
$R_{L}$	Load resistance	≥ 2	kΩ
$C_{L}$	Load capacitance	≤ 5	nF
$U_{c}$	Supply voltage (±10 %)	±15	V
$I_{\mathrm{C}}$	Current consumption @ $U_{\mathrm{C}}$	$35 + U_{\rm S}/R_{\rm L}$	mA

### Accuracy - Dynamic performance data

			Max	
$\varepsilon_{\mathrm{tot}}$	Total error @ $U_{PN}$ ,	$T_A = 25  ^{\circ}\text{C}$	±1	%
		−25 °C +70 °C	±2	%
$U_{0}$	Offset voltage @ $U_p$ = 0,	$T_A = 25  ^{\circ}\text{C}$	±30	mV
		−25 °C +70 °C	±60	mV
t <sub>D 90</sub>	Delay time to 90 % of the f	inal output value for $I_{\scriptscriptstyle \sf PN}$ :	step ¹)≈ 25	μs
BW	Frequency bandwidth (-3	3 dB) @ 50 % $U_{\scriptscriptstyle \sf PN}$	DC 11	kHz

General data			
$T_{A}$	Ambient operating temperature	<del>-</del> 25 +70	°C
$T_{Ast}$	Ambient storage temperature	<del>-</del> 40 +85	°C
$P_{P}$	Total primary power loss @ $U_{\sf PN}$	2.86	W
$R_{P}$	Resistance of primary (winding)	2.8	$M\Omega$
m	Mass	600	g
	Standards	EN 50155: 200°	7

Notes: 1) For a  $dv/dt = 1000 \text{ V/}\mu\text{s}$ .

#### **Features**

- Closed loop (compensated) voltage transducer
- Insulating plastic case recognized according to UL 94-V0.

### **Advantages**

- Very good linearity
- · Low thermal drift
- · Low delay time
- · High bandwith.

### **Applications**

- AC variable speed drives and servo motor drives
- Static converters for DC motor drives
- Uninterruptible Power Supplies
- Power supplies for welding applications
- Railway overhead line voltage measurement
- Single or three phase inverters
- Propulsion and braking choppers
- Propulsion converters
- Auxiliary converters
- Battery chargers.

### **Application Domains**

- Railway (fixed installations and onboard)
- Industrial.

EN 50121-3-2: 2016 2)

<sup>&</sup>lt;sup>2)</sup> Deviation of the offset during the test IEC 61000-4-3 between 100 to 300 MHz.



### **Voltage Transducer CV 4-4000**

Insulation coordination			
$U_{\rm d}$	RMS voltage for AC insulation test, 50 Hz, 1 min	9 <sup>1)</sup> <b>Min</b>	kV
$d_{\rm Cp}$	Creepage distance	188	mm
$d_{CI}$	Clearance	124	mm
CTI	Comparative tracking index (group I)	600	

Note: 1) Between primary and secondary.

### **Applications examples**

According to IEC 61010-1 standards and following conditions:

- Over voltage category OV 3
- Pollution degree PD2
- Non-uniform field

	IEC 61010-1
$d_{\mathrm{Cp}},d_{\mathrm{CI}},U_{\mathrm{Ni}}$	Nominal voltage
Basic insulation	1000 V
Reinforced insulation	1000 V

### Safety

This transducer must be used in limited-energy secondary circuits according to IEC 61010-1.



This transducer must be used in electric/electronic equipment with respect to applicable standards and safety requirements in accordance with the manufacturer's operating instructions.



Caution, risk of electrical shock

When operating the transducer, certain parts of the module can carry hazardous voltage (e.g. primary connections, power supply).

Ignoring this warning can lead to injury and/or cause serious damage.


This transducer is a build-in device, whose conducting parts must be inaccessible after installation.

A protective housing or additional shield could be used.

Main supply must be able to be disconnected.



### Dimensions CV 4-4000/SP1 (in mm)



#### **Mechanical characteristics**

General tolerance

Transducer fastening

Recommended fastening torque

Connection of primary

Connection of secondary

Recommended fastening torque 2.2 N·m

±0.5 mm

4 slots Ø 6.5 mm

4 M6 steel screws

5 N·m

M5 threaded studs

M5 threaded studs

#### **Remarks**

- $\bullet \ \ U_{\rm S}$  is positive when  $U_{\rm P}$  is applied on terminal +HT.
- Installation of the transducer must be done unless otherwise specified on the datasheet, according to LEM Transducer Generic Mounting Rules. Please refer to LEM document N°ANE120504 available on our Web site: .https://www.lem.com/en/file/3137/ download/